

**Regional Recreation Corporation of Wood Buffalo (“RRC”)  
Fort McMurray, Alberta  
Request for Proposal (“RFP”)  
For  
LED Retrofit**

**RFP # 2019-01-29-LED-Retrofit**

**ADDENDUM 1**

Responses from the Regional Recreation Corporation of Wood Buffalo (in red font) to the following questions received in relation to the aforementioned Request for Proposal are reflected in this Addendum.

1. Is the timeline for July 1<sup>st</sup>, 2019 flexible?

1 A. Prefer July 1<sup>st</sup> 2019 but can be flexible if this is not attainable.

2. Will as built for lights be provided?

2 A. See appendix C, D and E.

3. Do wall lights need to be replaced?

3 A. Yes including the wall lights in the curling rink.

4. Replace the high bay lights in front of guest services?

4 A. Yes.

5. Do you require replacing tubes or replacement of all fixtures?

5 A. We would like to have both options;

- Quote 1 to replace all fixtures
- Quote 2 to replace tube

6. Are lights 347volts?

6 A. All lights in the Fieldhouse, Hockey Arena, Hallways, Office Areas and Library are 347volts, there will be a small percentage 120 volts.

7. Clarify areas to be included, besides those in the RFP?

7 A. List of areas to be added to scope of work:

- Child Mind and Child Play
- All washrooms, dressing rooms and Aquatics change rooms
- Three (3) Dance studios and Art room
- Staff room
- Kitchen
- Wall lights in pool and curling rink
- Mi Café and Hockey Concession
- Lease spaces-Yogen Fruz, Clearwater Physical Therapy and Tweedy Nails

8. Should pot lights be changed?

8 A. No pot lights need to be changed, this includes the Frosty Fox restaurant.

9. What do you require for lighting levels?

9 A. All lighting levels should be based on current building code requirements for recreation facilities and included in the proposal.

10. What areas do not have to be part of the project?

10 A. Pool, curling rink, squash and racquet ball courts, climbing wall, exterior lights and leisure ice.

11. Dimmer switches in banquet rooms?

11 A. Yes all three banquet rooms should have dimmer lights.

12. What type of color should lights be?

12 A. Based on industry standard for offices, public areas and recreation facilities.

List of companies that attended mandatory meeting on Feb 4<sup>th</sup> 2019, 10:00 AM MST location, Suncor Community Leisure Centre:

1. Advantage Electric
2. ATT Electric Ltd.
3. BNV Mechanical Inc.
4. EECD electric
5. Gescan
6. GreenCo. LED & Solar
7. IME North
8. Nedco
9. Powermax Contracting
10. Prelim Electric
11. Stirling Construction
12. Tazi Electric Ltd.
13. Westward Electric