

**Regional Recreation Corporation of Wood Buffalo (“RRC”)
Fort McMurray, Alberta
Request for Proposal (“RFP”)
For
Training Pool / Filtration Upgrade**

RFP # 2019-04-02-Training-Pool-Filtration -Upgrade

ADDENDUM 1

Responses from the Regional Recreation Corporation of Wood Buffalo (in red font) to the following questions received in relation to the aforementioned Invitation to Bid are reflected in this Addendum.

- 1) Please confirm if AHS has reviewed the plan? If the intent is for the system flow rate to double to 676 GPM it would mean that the velocity in the 6" pool water supply line would be approx. 8.5ft/sec. This exceeds the current ABC by 1ft/sec. AHS will have to approve this change or the 6" pws would need to upsized to 8"?
Answer #1: Information sent, just waiting for the AHS for their approval.
- 2) Please confirm who will be carrying engineering costs?
Answer #2: The Proponent is responsible for stamped engineering drawing.
- 3) Who is responsible for start-up/commissioning of Training pool?
Answer #3: Proponent is responsible for start-up/commissioning.
- 4) Please confirm if pneumatic valves were provided with the defender filter? There should also be a gauge panel, tubing and RMF Controller supplied with the filter. Please confirm.
Answer #4: See photos below of all the component included on the filter, its look like everything are there.
- 5) Please confirm the repairs of the (2) compressors not in operation is outside the scope of this RFP?
Answer #5: Compressor is not included on the scope.
- 6) Please confirm filter media is supplied by RRCWB?
Answer #6: We have filter media for this filter.

