

**Regional Recreation Corporation of Wood Buffalo (“RRC”)  
Fort McMurray, Alberta  
Request for Proposal (“RFP”)  
For  
Renovation of Child Play Area Anzac Recreation Centre**

**RFP # 2019-04-22-Renovation-Child-Play-Area-Anzac-Recreation-Centre**

**ADDENDUM 2**

Responses from the Regional Recreation Corporation of Wood Buffalo (in red font) to the following questions received in relation to the aforementioned Invitation to Bid are reflected in this Addendum.

1) Close of questions date?

**Answer #2: The RRC has extended close of questions to May 3, 2019, 4:00PM MST.**

2) What voltage does the washer and dryer require?

**Answer #2: The dryer is a 30 AMP 240V plug and washer requires a regular plug.**

3) Confirm the location of the kid’s washrooms and requirements for sink and toilets?

**Answer #3: We are asking the Proponent to decide the best location for the washrooms, washer and dryer, double sink and dishwasher. The kids toilets dimensions: 24 1/2" x 19 1/2" x 26" and sink 21-1/2" High x 16" Wide x 12-3/4" Proj or as close as possible. The brand and style would be the Proponents decision.**

4) Can you provide drawings for drainage, plumbing, piping and ventilation; all mechanical?

**Answer #4: See appendix F.**